

# DAILY POOL LOG

Date \_\_\_\_\_

Facility Name \_\_\_\_\_

		Half an hour before opening, then every 2 hours			Daily					Weekly	Monthly	
Operator initials	Time	Free Available Chlorine min. 0.5 mg/l (min. 1.0 mg/l for stabilized chlorine)	pH 7.2 to 7.8	Bromine min. 2.0 mg/l	Total Bathers	Make-up water meter reading	Test of emergency telephone	Test of ground current leakage device	Total Chlorine	Cyanuric Acid max. 60 mg/l	Total Alkalinity min. 80 mg/l	Gravity & suction outlet covers inspected

Indicate each occurrence of an emergency, rescue or equipment break-down recording the incident and the action taken:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Comments \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

NOTE: Indicate each occurrence of an emergency, rescue or equipment break-down recording the incident and the action taken in the 'comments' section. Retain log for one year.